

## ANALYTICAL REPORT

Mr. Richard Tyler  
MILBANK MANUFACTURING INC  
1400 E. Havens Street  
Kokomo, IN 56901-3188

10/18/2000

Job Number: 00.05290

Page 1 of 3

Enclosed are the Analytical Results for the following samples  
submitted to TestAmerica, Inc. Indianapolis Division for analysis:

Project Description: WASTEWATER ANALYSIS

Sample Number	Sample Description	Date Taken	Time Taken	Date Received
276992	WEEKLY	09/29/2000	11:30	09/29/2000
276993	TANK #2	09/29/2000	11:30	09/29/2000
276994	TANK #5	09/29/2000	11:30	09/29/2000

TestAmerica, Inc. certifies that the analytical results contained  
herein apply only to the specific samples analyzed.

TestAmerica Incorporated-Indianapolis Division is in compliance with  
the National Environmental Laboratory Accreditation Program (NELAP)  
Standards.

Reproduction of this analytical report is permitted only in its  
entirety.

MIL0003777

## ANALYTICAL REPORT

Mr. Richard Tyler  
MILBANK MANUFACTURING INC  
1400 F. Havens Street  
Kokomo, IN 46901-3188

10/18/2000

Job No.: 00.05290

Page 2 of 3

Date Received: 09/29/2000

Job Description: WASTEWATER ANALYSIS

Sample Number / Sample I.D.	Sample Date/	Analyst		Reporting
Parameters	Units	Date & Time Analyzed	Method	Limit
276992 WFFKI Y	09/29/2000 11:30			
Zinc, ICP	0.037	mg/L	tyj 10/16/2000 20:38 EPA 200.7	<0.020
276993 TANK #2	09/29/2000 11:30			
Zinc, ICP	1.8	mg/L	tyj 10/16/2000 20:47 EPA 200.7	<0.020
276994 TANK #5	09/29/2000 11:30			
Zinc, ICP	44.	mg/L	tyj 10/16/2000 21:06 EPA 200.7	<0.020

MIL0003778

Page 3 of 3

## KEY TO ABBREVIATIONS

- < Less than; when appearing in the result column, indicates analyte not detected at or above the Reporting Limit.
- % Percent; To convert ppm to %, divide result by 10,000. To convert % to ppm, multiply the result by 10,000.
- \*
- Indicates the Reporting Limit is elevated due to insufficient sample volume.
- mg/l Part per million; Concentration in units of milligrams of analyte per liter of aqueous sample.
- ug/L Part per billion; Concentration in units of micrograms of analyte per Liter of aqueous sample.
- mg/kg Part per million; Concentration in units of milligrams of analyte per kilogram of non-aqueous sample.
- ug/kg Part per billion; Concentration in units of micrograms of analyte per kilogram of non-aqueous sample.
- a Indicates the sample concentration was quantitated using a diesel fuel standard.
- b Indicates the analyte of interest was also found in the method blank.
- c Sample resembles unknown Hydrocarbon.
- dw When indicated, the result is reported on a dry weight basis. The contribution of the moisture content in the sample has been subtracted when calculating the concentration.
- d1 Indicates the analyte has elevated Reporting Limit due to high concentration.
- d2 Indicates the analyte has elevated Reporting Limit due to matrix.
- e Indicates the reported concentration is estimated.
- g Indicates the sample concentration was quantitated using a gasoline standard.
- h Indicates the sample was analyzed past recommended holding time.
- i Insufficient spike concentration due to high analyte concentration in the sample.
- j Indicates the reported concentration is below the Reporting Limit.
- k Indicates the sample concentration was quantitated using a kerosene standard.
- l Indicates an MS/MSD was not analyzed due to insufficient sample. An LCS / LCS Duplicate provided for precision.
- m Indicates the sample concentration was quantitated using a mineral spirits standard.
- o Indicates the sample concentration was quantitated using a motor oil standard.
- p Indicates the sample was post spiked due to sample matrix.
- q Indicates MS/MSD exceeded control limits. The associated sample may exhibit similar matrix bias. All other quality control indicators are in control.
- r Indicates the sample was received past recommended holding time.
- u Indicates the sample was received improperly preserved and/or improperly contained.
- uj Indicates the result is below the Reporting Limit and is considered estimated.

MIL0003779

TestAmerica, Inc. Indianapolis Division  
6964 Hillside Ct., Indianapolis, IN 46250  
Phone: (317) 842-4261 FAX: (317) 842-4286

---

TO: STEPHANIE  
COMPANY: MILBANK MANUFACTURING INC

FROM: Josh Dutton  
COMPANY: Indianapolis Division  
PHONE: (317)842-4261

SENT ON: Mon Oct 23 08:15:08 2000

NUMBER OF PAGES (INCLUDING COVER): 4

COMMENTS:

---

---

PLEASE CALL NUMBER ABOVE IF FAX TRANSMISSION IS INCOMPLETE.

This material is intended only for the use of the individual or entity to whom it is addressed, and may contain information that is privileged and confidential. If you are not the intended recipient, or the employee or agent responsible for delivering this material to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone at the following toll free number 1-800-485-0204.

MIL0003780

DATE: SEPTEMBER 28<sup>TH</sup>, 2000

**MILBANK MANUFACTURING COMPANY**

TIME	METER READING	INITIALS
7:30	67010	SLH
8:00	67230	SLH
8:30	67450	SLH
9:00	67670	SLH
9:30	67780	SLH
10:00	67900	SLH
10:30	68170	SLH
11:00	68390	SLH
11:30	68600	SLH
12:00	68810	SLH
12:30	69040	SLH
1:00	69240	SLH
1:30	69380	SLH
2:00	69580	SLH
2:30	69840	SLH
3:00	70000	SLH
3:30	70210	SLH

9-28-00

## PART I

Please test for the following highlighted + there a 2 grab samples from tank 2 + tank 5 that needs a zinc test ran on them.

## A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Thank-you.

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

Discharge LimitationsMonitoring Requirements

<u>Regulated Parameter</u>	<u>Maximum for Any one Day mg/L</u>	<u>Monitoring Frequency</u>	<u>Sample Type</u>
Cadmium[5]	.02	Semi-Annual	Composite[2]
Total Chromium[5]	2.0	Semi-Annual	Composite[2]
Copper[5]	0.60	Semi-Annual	Composite[2]
Cyanide	0.50	Semi-Annual	Grab
Lead[5]	0.10	Semi-Annual	Composite[2]
Nickel[5]	0.80	Semi-Annual	Composite[2]
Silver[5]	0.24	Semi-Annual	Composite[2]
Zinc[5]	1.25	1 X Week	Composite[2]
Oil and Grease[6]	100	Semi-Annual	Grab
TPH[6]	(Monitor and report)	Semi-Annual	Grab
pH	6-10	Daily	Grab
CBOD [4]	(Monitor and report)	1 X Month	Composite[2]
Ammonia [4]	(Monitor and report)	1 X Month	Composite[2]
COD [4]	(Monitor and report)	1 X Month	Composite[2]
TSS [4]	(Monitor and report)	1 X Month	Composite[2]
Flow	N/A	Daily [3]	
TTO	2.13	Semi-Annual	Grab
Phenol	0.50	Semi-Annual	Grab
Molybdenum[5]	(Monitor and report)	1 X Month	Composite[2]

DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 1 DAY-OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

## PART I

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

#### Discharge Limitations

#### Monitoring Requirements

	Regulated Parameter	Maximum for Any one Day mg/L	RESULT	DATE TAKEN	Monitoring Frequency	Sample Type
Cd	Cadmium[5]	.02			Semi-Annual	Composite[2]
Cr	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
Cu	Copper[5]	0.60			Semi-Annual	Composite[2]
Ca	Cyanide	0.50			Semi-Annual	Grab
Pb	Lead[5]	0.10			Semi-Annual	Composite[2]
Ni	Nickel[5]	0.80			Semi-Annual	Composite[2]
Ag	Silver[5]	0.24			Semi-Annual	Composite[2]
Zn	Zinc[5]	1.25	0.037	9-28-00	1 X Week	Composite[2]
FOG	Oil and Grease[6]	100			Semi-Annual	Grab
Oil + GREASE HYDROCARBONS	TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pH	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)			1 X Month	Composite[2]
Nh3	Ammonia [4]	(Monitor and report)			1 X Month	Composite[2]
	COD [4]	(Monitor and report)			1 X Month	Composite[2]
	TSS [4]	(Monitor and report)			1 X Month	Composite[2]
	Flow	N/A			Daily [3]	
* TTO		2.13			Semi-Annual	Grab
	Phenol	0.50			Semi-Annual	Grab
Mo	Molybdenum[5]	(Monitor and report)			1 X Month	Composite[2]

END TTO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR  
CATEGORICAL STATEMENT. MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

MIL0003783

DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 5 DAY OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

## PART I

### A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below:

#### Discharge Limitations

#### Monitoring Requirements

	Regulated Parameter	Maximum for Any one Day mg/L	RESULT	DATE TAKEN	Monitoring Frequency	Sample Type
Cd	Cadmium[5]	.02			Semi-Annual	Composite[2]
Cr	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
Cu	Copper[5]	0.60			Semi-Annual	Composite[2]
Ca	Cyanide	0.50			Semi-Annual	Grab
Pb	Lead[5]	0.10			Semi-Annual	Composite[2]
Ni	Nickel[5]	0.80			Semi-Annual	Composite[2]
Ag	Silver[5]	0.24			Semi-Annual	Composite[2]
Zn	Zinc[5]	1.25	0.037	9-28-00	1 X Week	Composite[2]
FOG	Oil and Grease[6]	100			Semi-Annual	Grab
Oil + GREASE HYDROCARBONS	TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pH	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)			1 X Month	Composite[2]
Nh3	Ammonia [4]	(Monitor and report)			1 X Month	Composite[2]
	COD [4]	(Monitor and report)			1 X Month	Composite[2]
	TSS [4]	(Monitor and report)			1 X Month	Composite[2]
	Flow	N/A			Daily [3]	
*	TTO	2.13			Semi-Annual	Grab
	Phenol	0.50			Semi-Annual	Grab
Mo	Molybdenum[5]	(Monitor and report)			1 X Month	Composite[2]

END TTD CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR CATEGORICAL STATEMENT. MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

MIL0003784